

TOWN OF HOT SPRINGS
Montana Public Water Supply ID number 00251
2015 Water Quality Report

In compliance with the EPA's Safe Drinking Water Act and in an effort to keep you informed about the quality of water and services we provide to you each day, we're pleased to provide you with our Annual Water Quality Report. This report is a snapshot of the quality of water we provided you last year. It includes details regarding the source of your water, what your water contains and how it compares to EPA and the State of Montana standards.

Our drinking water comes from three wells that are 241, 383, and 807 feet deep. We have 400 service connections and added no new connections last year. We want you, our valued customers, to be informed about your water utility. If you want to learn more, please attend any of our regularly scheduled town council meetings held on the first Tuesday of each month at 7:00 p.m. in Town Hall at 109 Main Street. In a continuing effort to maintain and improve our water system, we added a new 200,000 gallon storage tank, new fire hydrants east of the High School, and new SCADA radio system and controls.

We are pleased to report that our drinking water is safe and meets all federal and state requirements. If you have any questions about this report or concerning your water utility, please contact Gerald Kontos, our utility clerk at (406) 741-2353. Ruben Loberg and Sierra Lazaro are our certified operators with five and four years of experience. They attend periodic training sessions to meet continuing education requirements. The most recent training course they attended was in May of 2015 and the topics included the new Revised Total Coliform Rule (RTCR).

DID YOU KNOW? The sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, and wells. As water travels over the surface of land or through the ground, it dissolves naturally occurring minerals and in some cases radioactive elements. Water can also pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in water include:

- 1) Microbial contaminants such as viruses and bacteria which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife
- 2) Inorganic contaminants, such as salts and metals which can be naturally occurring or result from urban storm water runoff, industrial or domestic waste water discharges, oil and gas production, mining and farming.
- 3) Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- 4) Volatile organic chemicals, which are byproducts of industrial processes, petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- 5) Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health. We routinely monitor for constituents in your drinking water according to Federal and State laws. Our sampling frequency complies with EPA and state drinking water regulations. The following tests were performed to identify possible contaminants in our system during the period of January 1 to December 31, 2015:

- 15 coliform bacteria tests - all were coliform free.
- 1 Nitrate plus Nitrite test on each of our three wells - none was detected.

Due to the purity of our water, we have applied for and been issued a monitoring waiver for ten inorganic contaminants for all three of our wells. This waiver allows our system to sample only once every nine years for these contaminants.

The following table lists the contaminants detected during recent testing. Some of the data in this table may be more than one year old, since certain chemical contaminants are monitored less than once per year.

Regulated Contaminants

CONTAMINANT	VIOLATION Y/N	SAMPLE DATE	HIGHEST LEVEL DETECTED	UNIT MEASUREMENT	MCLG	MCL	LIKELY SOURCE OF CONTAMINATION
Alpha Emitters Well #1 Well #2 Well #3	N	7-8-13	1.2 +/- 1.2 2.1 +/- 1.2 8.4 +/- 1.7	pCi/L	0	15	Erosion of natural deposits
Copper	N	7-10-13	90th % is 0.02	ppm	1.3	AL= 1.3	Corrosion of Household plumbing systems: Erosion of natural deposits: Leaching from wood preservatives
Fluoride Well #1 Well #2 Well #3	N	2-11-12 2-11-12 2-11-12	1.55 1.29 0.53	ppm	4	4	Erosion of natural deposits; Water additive which promotes strong teeth: Discharge from fertilizer and aluminum factories
Radium 226 Well #1 Well #3	N	7-8-13	0.2 1.1	pCi/L	0	5	Natural deposits
Radium 228 Well #1 Well #3	N	3-20-03 4-3-06	1.0 2.5	pCi/L	0	5	Natural deposits

DEFINITIONS:

MCL - Maximum Contaminant Level - The “Maximum Allowed” is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MCLG - Maximum Contaminant Level Goal - The “Goal” is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

PPM - Parts per million or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

PPB - Parts per billion or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

AL - Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

pci/L - Pico Curies per Liter - a very small unit of measurement of radioactivity.

What does this table tell us?

As you can see our system had no MCL violations. MCL's are set at very stringent levels. To understand the possible health effects of exceeding the MCL, a person would have to drink two liters of water every day at the MCL for a lifetime to have a one in a million chance of having any adverse health effects. Although we have learned through our monitoring and testing that some constituents have been detected, the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We are required to test for coliform bacteria once per month. Due to a data transmission error, the Montana Department of Environmental Quality (MTDEQ) did not get the results of our September 2015 sample entered into their computer database. We were notified of this and received a failure to monitor violation letter from MTDEQ in October. We had the laboratory resend the data to MTDEQ, and the violation was rescinded in October.

All sources of drinking water are subject to potential contamination by contaminants that are naturally occurring or man made. Those contaminants can be microbes, organic or inorganic chemicals, or radioactive materials. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791, or online at www.epa.gov/safewater.

Lead in drinking water comes primarily from materials and components of the service lines and home plumbing systems. It is possible that lead levels at your home may be higher than other homes in the community as a result of materials used in your home's plumbing. Our water system is responsible for providing high quality drinking water, but we cannot control the variety of materials used in private home plumbing systems. If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested by a certified laboratory like the one we send our samples to (Montana Environmental Laboratory, 406-755-2131). When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap until the water temperature has stabilized (usually for 30 seconds to 2 minutes) before you use the water for drinking or cooking. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure to lead is available from the Safe Drinking Water Hotline 1-800-426-4791, or online at www.epa.gov/safewater/lead.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline, or online at www.epa.gov/safewater.

In July of 2003, the Montana Department of Environmental Quality conducted a source water assessment of our system. This report provides additional information on the potential vulnerability of our wells to contamination. This report is available for review at City Hall. It is also available online at <http://svc.mt.gov/deq/dst/#/app/swp>. The report can be summarized in the following table:

Significant Potential Contaminant Sources

Source	Contaminant	Hazard	Hazard Rating	Barriers	Susceptibility	Management
Well #1	Pathogens, NO ₂ , etc.	Leakage into Well	High to Moderate	Multiple	Moderate to Low	Well Head Protection Program Ordinance
Well #2	Pathogens, NO ₂ , etc.	Leakage into Well	High to Moderate	Multiple	Moderate to Low	Well Head Protection Program Ordinance
Well #3	NA	NA	NA		Very Low	Well Head Protection Program Ordinance

Our water system is committed to providing our customers with safe, pure water and we are pleased that our water meets or exceeds all established state and federal standards. Thank you for reviewing this report.

Prepared by Montana Environmental Lab, LLC 3/16